

TEST CERTIFICATE

Issued to: Polar Switchgear Manufacturing LLC
PO Box: 3756
Sharjah, United Arab Emirates

For the product: Low-voltage switchgear and controlgear assembly

Trade name: Polar Switchgear Manufacturing LLC

Type/Model: Polar Power Master 3200 A MDB/MCC/SMDB/ATS

Ratings: I_{nA} 3200 A (at 50 °C ambient), U_e 415 V,
 U_i up to 1000 V, U_{imp} up to 12 kV,
IP54, IK10 (maximum),
Form 4b Type 6 /Type 7 and Form 2b
 I_{cw} 65 kA - 3 s, I_{cc} max, 65 kA at 415 V
For more details see annex

Manufactured by: Polar Switchgear Manufacturing LLC
Street 8, PO Box 3756, Industrial Area No.5
Sharjah, United Arab Emirates

Subject: Design verification

Requirements: IEC 61439-2:2020 edition 3.0
Clauses 8.101, 10.2, 10.3, 10.4, 10.5, 10.6, 10.7, 10.8, 10.9, 10.10, 10.11, 10.12

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 4600157.07-INC, dated 30 September 2022.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 30 September 2022

Number: 4600157.106

DEKRA Certification B.V.



H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed